

3/71

C147

Hohegan

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

P 933

OWNER		NAME Bruce Rabidou		ADDRESS Hillside Ave & Ridge Road, Mahopac Falls					
LOCATION OF WELL		(No. & Street) Hillside Ave & Ridge Rd			(Town) Carmel		(Lot Number) 122-27		
PROPOSED USE OF WELL		<input checked="" type="checkbox"/> DOMESTIC		<input type="checkbox"/> BUSINESS ESTABLISHMENT		<input type="checkbox"/> FARM		<input type="checkbox"/> TEST WELL 620 S	
		<input type="checkbox"/> PUBLIC SUPPLY		<input type="checkbox"/> INDUSTRIAL		<input type="checkbox"/> AIR CONDITIONING		<input type="checkbox"/> OTHER (Specify)	
DRILLING EQUIPMENT		<input type="checkbox"/> POTARY		<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION		<input type="checkbox"/> CABLE PERCUSSION		<input type="checkbox"/> OTHER (Specify)	
CASING DETAILS		LENGTH (feet) 120		DIAMETER (Inches) 6		WEIGHT PER FOOT 19		<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	
								DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
YIELD TEST		<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED		<input checked="" type="checkbox"/> COMPRESSED AIR		HOURS		G.P.M.	
								YIELD (G.P.M.) 2	
WATER LEVEL		MEASURE FROM LAND SURFACE - STATIC (Specify feet) 70		DURING YIELD TEST (feet) Total Drawdown		Depth of Completed Well In feet below Land surface: 485			
SCREEN DETAILS		MAKE						LENGTH OPEN TO AQUIFER (feet)	
		SLOT SIZE		DIAMETER (Inches)		IF GRAVEL PACKED:		Diameter of well including gravel pack (Inches):	
								GRAVEL SIZE (Inches) FROM (feet) TO (feet)	
DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION				Sketch exact location of well with distances, to at least two permanent landmarks.			
0 80		clay overburden							
80 105		brown sandstone							
105 485		gray granite							
If yield was tested at different depths during drilling, list below									
FEET		GALLONS PER MINUTE							
DATE WELL COMPLETED July 6, 1984		DATE OF REPORT 7-11-84		WELL DRILLER (Signature) 					